

1st Sampling 9/6/17 Results Received 9/20/17

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)
530900850020000	0001	Main Building	09/07/2017	06:39 am	David Wheeler	7091114-09	DF04 - 1	DF - Drinking Fountain	9/6/2017	9:00 PM	First Draw	250	PDC Laboratories, Inc.	EPA 200.8	ND
530900850020000	0001	Main Building	09/07/2017	06:31 am	David Wheeler	7091114-10	DF04 - 2	DF - Drinking Fountain	9/6/2017	9:00 PM	Flush	250	PDC Laboratories, Inc.	EPA 200.8	1.36
530900850020000	0001	Main Building	09/07/2017	06:35 am	David Wheeler	7091114-07	DF03 - 1	DF - Drinking Fountain	9/6/2017	9:00 PM	First Draw	250	PDC Laboratories, Inc.	EPA 200.8	1.94
530900850020000	0001	Main Building	09/07/2017	06:37 am	David Wheeler	7091114-08	DF03 - 2	DF - Drinking Fountain	9/6/2017	9:00 PM	Flush	250	PDC Laboratories, Inc.	EPA 200.8	3.95
530900850020000	0001	Main Building	09/07/2017	06:41 am	David Wheeler	7091114-03	DF01 - 1	DF - Drinking Fountain	9/6/2017	9:00 PM	First Draw	250	PDC Laboratories, Inc.	EPA 200.8	ND
530900850020000	0001	Main Building	09/07/2017	06:41 am	David Wheeler	7091114-04	DF01 - 2	DF - Drinking Fountain	9/6/2017	9:00 PM	Flush	250	PDC Laboratories, Inc.	EPA 200.8	ND
530900850020000	0001	Main Building	09/07/2017	06:46 am	David Wheeler	7091114-11	KITCHEN 01-1	KS - Kitchen Sink	9/6/2017	9:00 PM	First Draw	250	PDC Laboratories, Inc.	EPA 200.8	5.05
530900850020000	0001	Main Building	09/07/2017	06:47 am	David Wheeler	7091114-12	KITCHEN 01-2	KS - Kitchen Sink	9/6/2017	9:00 PM	Flush	250	PDC Laboratories, Inc.	EPA 200.8	ND
530900850020000	0001	Main Building	09/07/2017	06:50 am	David Wheeler	7091114-13	KITCHEN 02-1	KS - Kitchen Sink	9/6/2017	9:00 PM	First Draw	250	PDC Laboratories, Inc.	EPA 200.8	1.65
530900850020000	0001	Main Building	09/07/2017	06:53 am	David Wheeler	7091114-14	KITCHEN 02-2	KS - Kitchen Sink	9/6/2017	9:00 PM	Flush	250	PDC Laboratories, Inc.	EPA 200.8	7.50
530900850020000	0001	Main Building	09/07/2017	06:54 am	David Wheeler	7091114-05	DF02 - 1	DF - Drinking Fountain	9/6/2017	9:00 PM	First Draw	250	PDC Laboratories, Inc.	EPA 200.8	ND
530900850020000	0001	Main Building	09/07/2017	06:54 am	David Wheeler	7091114-06	DF02 - 2	DF - Drinking Fountain	9/6/2017	9:00 PM	Flush	250	PDC Laboratories, Inc.	EPA 200.8	1.01
530900850020000	0001	Main Building	09/07/2017	06:58 am	David Wheeler	7091114-01	MP01 - 1	KS - Kitchen Sink	9/6/2017	9:00 PM	First Draw	250	PDC Laboratories, Inc.	EPA 200.8	1.36
530900850020000	0001	Main Building	09/07/2017	06:59 am	David Wheeler	7091114-02	MP01 - 2	KS - Kitchen Sink	9/6/2017	9:00 PM	Flush	250	PDC Laboratories, Inc.	EPA 200.8	ND

2nd Sampling 10/16/17 Results Received 10/31/17

Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)
7102955-01	KITCHEN 01-1	KS - Kitchen Sink	10/16/2017	9:00 PM	First Draw	250	PDC Laboratories Inc.	EPA 200.8	2.04
7102955-02	KITCHEN 01-2	KS - Kitchen Sink	10/16/2017	9:00 PM	Flush	250	PDC Laboratories Inc.	EPA 200.8	ND
7102955-03	KITCHEN 02-1	KS - Kitchen Sink	10/16/2017	9:00 PM	First Draw	250	PDC Laboratories Inc.	EPA 200.8	3.51
7102955-04	KITCHEN 02-2	KS - Kitchen Sink	10/16/2017	9:00 PM	Flush	250	PDC Laboratories Inc.	EPA 200.8	1.87

2 KITCHEN FAUCETS WERE REPLACED BY TWINI PLUMBERS CORRECTING THE ISSUE.

EPA LIMIT FOR MUNICIPAL WATER IS UNDER 15 ug/L